

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 107Dated: 05/03/2025

It is certified that an inspection team headed by Ashok Mukati Assistant Engineer
(Name of Officers with designation) from P.H.E. Sub. Dn Damoh

PHED inspected the **St. Norbert School, Maganj Ward no. 04, Shanti Niketan, Damoh, Dist. - Damoh, MP** on 05/03/25 and on the basis of Water Test Report (Attached) bearing no. 02 dated 04/03/25 of District Water testing Laboratory Damoh (PHED Lab) certified that the **St. Norbert School, Maganj Ward no. 04, Shanti Niketan, Damoh, Dist. - Damoh, MP** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 05/03/2025 to 04/03/2026

Signature with seal

:-

Name

:- Shri G.S. Rawat

Designation

:- Executive EngineerName & address of the office/Department :- P.H.E. Division Damoh

To,

**St. Norbert School, Maganj Ward no. 04,
Shanti Niketan, Damoh, Dist. - Damoh, MP**
(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

Azulanandn
MANAGER
St. Norbert School
Maganj Ward No. 4 DAMOH (M.P.)

[Signature]
DIRECTOR/SECRETARY
(CHIEF FUNCTIONARY)
THE SOCIETY OF THE ABBEY OF BERNE INDIA
REG. NO.-1 OF 1940-41
ST. NORBERT ABBEY JAMTARA JHARKHAND

[Signature]
Principal
ST. NORBERT SCHOOL
Shanti Niketan, Maganj 04
Damoh- 470 661 (M.P.)

Distirct WATER TESTING LABORATRY
Public Health Engineering Department Damoh
Test report

Sample Detail

No. - 02

District	Damoh	Block	Damoh nagar.
Panchayat	Damoh nagar	Village	Damoh nagar

Nature of Sample:-Drinking Water sample/ Other

Name of source	TW/BW/DW	Quantity of Sample	Ok
Date of analysis started	03/03/2025	Date of analysis completed	04/03/2025

Particulars of Samples :-

1.St.Norbert School maganj ward 04 Damoh

2.

3.

Test Result

S.no	Characteristics and unit	BIS-10500:2012 Reaffirmed in June 2015		Results		
		Acceptable Limit	Permissible Limit	1	2	3
Physical test						
1	Temperature in degree C	--	--			
2	Colour in Hazen scale	5	15	--		
3	Odour	Agreeable	Agreeable	--		
4	Turibidity in NTU	1.0	5.0	2.7		
Chemical test						
5	pH value	6.5 to 8.5	6.5 to 8.5	7.19		
6	TDS Mg/L	500	2000	183.8		
7	Total Hardness as caco3 Mg/L	200	600	94		
8	Alkalinity as caco3 in Mg/L	200	600	64		
9	Chloride as Cl in Mg/L	250	1000	30		
10	Fluoride as F in Mg/l	1.0	1.5	0.21		
11	Iron as Fe in Mg/L	0.3	1.0	0.1		
12	Nitrate as NO3 in Mg/L	45	45	--		
13	Sulphate as SO4 in Mg/L	200	400	26.3		
14	Mangnese as Mn in Mg/l	0.1	0.3	--		
Bacterological Test						
15	Total Coliform Per 100 ml	NIL	NIL	Nil		

1. This report should not be produced partly or full without approval of signatory authority for legal purpose. .

2. It is recommended that acceptable limit is to be implemented. values of excess of those mentioned under acceptable render the water are not suitable. but still may be tolerated in the absence of an alternative source but up to the limit indicated under the permissible limit in the absence of alternative source in column 5, above which the sources will have to be rejected.

3. The results refer only to tested sample and parameters tested.

4. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Lasati
Chemist
P.H.E.Sub-Dn.Damoh

Assistant Engineer
Assistant Engineer
P.H.E.Sub-Dn.Damoh

Arulanantham
MANAGER
St. Norbert School
Maganj Ward No.4 DAMOH(M.P.)

Principal
Principal
ST. NORBERT SCHOOL
Shanti Niketan, Maganj 04
Damoh- 470 661 (M.P.)

Director/Secretary
DIRECTOR/SECRETARY
(CHIEF FUNCTIONARY)
THE SOCIETY OF THE ABBEY OF BERNE INDIA
REG. NO.-1 OF 1940-41
ST. NORBERT ABBEY JAMTARA, JABALPUR